



ELEVATION NOTES

- THIS DRAWING IS FOR DIAGRAMMATIC PURPOSES ONLY. FOR ACTUAL HANDING AND SWING REFERENCE FLOOR PLANS.
- DIMENSIONS SHOWN FOR COORDINATION ONLY. EXACT LOCATIONS AND MOUNTING HEIGHTS TO BE FIELD COORDINATED WITH OWNER AND ARCHITECT.
- IF INSTALLATION IS ABOVE A FINISHED CEILING, CONDUIT IS NOT REQUIRED FOR THIS CABLE RUN. USE PLENUM CABLE.
- IF INSTALLATION IS ABOVE A FINISHED CEILING, STUB CONDUIT, w/PULL STRING, 6" ABOVE FINISHED CEILING.
- ALL CONDUIT IS 3/4" UNLESS OTHERWISE NOTED.
- FOR GROUTED DOOR FRAMES, PROVIDE CONDUIT INTO SPECIAL STEEL BOX OR STYROFOAM BLOCK TO FACILITATE BOTH INSTALLATION AND SERVICE. DOOR CORDS ARE NOT ACCEPTABLE.
- MOUNT 10"x10"x4" JUNCTION BOX ON THE SECURED SIDE BEHIND THE CARD READER. IF FIELD CONDITIONS PROHIBIT INSTALLATION, MOUNT PER FACILITIES ELECTRONICS SHOP APPROVED LOCATION.

BB-5

DOUBLE DOOR, CARD IN/FREE EXIT
ELECTRIC PANIC w/REX SWITCH, MANUAL PANIC w/REX SWITCH
LOCAL NOISE (SIREN & PIEZO), FAIL SECURE
ELEVATION

SCALE: N.T.S.

LBNL ELECTRICAL STANDARDS
SECURITY CARD ACCESS BB-5
DOUBLE DOOR, CARD IN/FREE EXIT ELECTRIC LOCKSET

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY
FACILITIES DIVISION

DRAWN BY	DATE
CHECKED BY	
APPROVED BY	
CAD FILE PATH	
SCALE	NTS
DRAWING NO.	SHEET
SEC114A	BB-5
PROJECT NO.	